

No. CE/Testing-QC/Vendor/

Date

To,

M/s. KEBEE Power Transformer Pvt. Ltd.,
E-56, Additional Ambarnath Industrial Area,
Ambarnath (East)

25577

6 SEP 2019

Sub: Vendor Approval of M/s. KEBEE Power Transformer Pvt. Ltd., for supply of Three phase, 315KVA & 630 KVA, 22/0.433 KV, Copper wound, CRGO core, Distribution Transformers (EEL-2) under DDUGJY/IPDS schemes.

- Ref- 1) Online item Registration code - 3020
2) Vendor letter no Nil dt. 29.07.2019
3) MoM dt. 16.03.2019
4) CE/Testing & QC/MSD-I/Dist. dt. 29.08.19
5) Dir.(Op)/1344 dt. 09.09.19

Dear Sir,

In connection with the above, and request furnished by you vide ref (1& 2), this office has evaluated the proposal & pleased to accord the approval as MSDCL approved vendor for supply of Three phase, 315KVA & 630 KVA, 22/0.433 KV, Copper wound, CRGO core, Distribution Transformers (EEL-2) under DDUGJY/IPDS schemes.

The details of Drawings are as follows:

Three phase, 315KVA & 630 KVA, 22/0.433 KV, Copper wound, CRGO core, Distribution Transformers (EEL-2) under DDUGJY/IPDS schemes			
sr.no.	Description	Drawing Nos.	Drawing Nos
		630 KVA, 22/0.433 KV	315 KVA, 22/0.433 KV
	GTP	1-2 pages	1-2 pages
1	Rating and Terminal Plate Drawing	KB/630/22/433/NP/01	KB/315/22/433/NP/01
2	G. A. Drawing	KB/630/22/433/GA/04	KB/315/22/433/GA/04
3	Internal Construction Drawing.	KB/630/22/433/IC/03	KB/315/22/433/IC/03
4	Technical Detail Drawing	KB/630/22/433/TD/02	KB/315/22/433/TD/02
5	H.V. Bushing Assembly & Creepage (24KV/250A) Drawing	KB/630/22/433/HB/05	KB/315/22/433/HB/05
6	L.V. Bushing Assembly & Creepage (1KV/630A) Drawing	KB/630/22/433/LB/06	KB/315/22/433/LB/06
7	Silica Gel Breather Drawing 250 grm	KB/630/22/433/BREA THER/07	KB/315/22/433/BREA THER/07

The above GTP & Drawings of are found generally in order as per MSDCL technical specifications and IS:1180 amended up to date, hence it is technically acceptable.